

DATA SHEET

GFS810 ABB Ability™ System 800xA® hardware selector



Select I/O is an Ethernet networked, single channel granular I/O system for the ABB Ability[™] System 800xA automation platform. Select I/O helps decouple project tasks, minimizes the impact of late changes, and supports standardization of I/O cabinetry ensuring automation projects are delivered on time and under budget. A Signal Conditioning Module (SCM) performs the necessary signal conditioning and powering of the connected field device for one I/O channel.

The GFS810 provides ground fault detection for signals with field supply sources from external power injection.

Features and benefits

- Ground fault detection for signals with field supply sourced from external power injection.
- Measuring of resistance to ground to provide it as an analog value to the application.
- Can be used with all GIO module types (GIS810 and GIS880).
- Galvanic isolation.

Diagnostics:

- Line break supervision of ground connection.
- Internal self-test.
- Test option for ground fault detection function (through external button).
- LED indicators on the SCM indicate the operational state of the module.

| General info | | |
|----------------------|-------------------------------|--|
| Article number | 3BSE093005R1 | |
| Туре | Ground Fault Detection Module | |
| Number of channels | 1 | |
| Signal specification | 01 Mohm | |
| HART | N/A | |
| SOE | N/A | |
| Redundancy | No | |
| Hot swap | Yes | |
| High integrity | No | |
| Intrinsic safety | No | |
| Mechanics | Select I/O | |

| Detailed data | | |
|------------------------------------------|------------------------------------------------------------------------------------------|--|
| Supported field devices | - | |
| Isolation | Galvanic isolation to system. Routine tested at factory with 3060 VDC. | |
| Field power | - | |
| Accuracy | ±15 % | |
| Diagnostics | Internal hardware supervision Communication supervision Internal power supervision | |
| Calibration | Factory calibration | |
| Power dissipation | 0.4 W | |
| Installation in Hazardous Area/Locations | Yes/Yes (on IPA) | |
| IS barrier | No | |
| Field Input Robustness | ±35 V between all terminals | |
| Input voltage range | 19.230 V | |

| Environment and certification | |
|---------------------------------|-------------------------------------------------------------------------------------------------------------------------------|
| Temperature, Operating | -40 °C (-40 °F) to +70 °C (158 °F) |
| Temperature, Storage | -40 °C (-40 °F) to +85 °C (185 °F) |
| Pollution degree | Pollution Degree 2 acc. to IEC 60664-1 |
| Relative humidity | 5 to 95 %, non-condensation |
| Altitude | -1000 to 5000 m (restrictions apply) |
| Mechanical operating conditions | IEC 61131-2 |
| EMC | IEC/EN 61000-6-4, IEC/EN 61000-6-2 |
| Overvoltage categories | Category II acc. to IEC 60664-1 |
| Protection class | IP20 acc. to IEC 60529 |
| CE-marking | Yes |
| UKCA | Yes |
| Electrical Safety | IEC/EN 61010-1 UL 61010-1 CSA-C22.2 No. 61010-1-12 IEC/EN 61010-2-201 UL 61010-2-201 CSA C22.2 No. 61010-2-201 |
| Marine certification | N/A |
| Corrosive atmosphere | G3 |
| RoHS compliance | EU ROHS, UAE ROHS, CN ROHS |
| WEEE compliance | EU |
| Hazardous Area ATEX | II 3G Ex ec IIC T4 Gc II 3G Ex ic ec IIC T4 Gc |
| Hazardous Area IECEx | Available on IPA: II 3G Ex ec IIC T4 Gc II 3G Ex ic ec IIC T4 Gc |
| Hazardous Location US/CAN | Available on IPA: cULus CL I, ZN 2, AEx ec IIC T4 Gc, Ex ec IIC T4 Gc X CL I, DIV 2, Groups A-D T4 |
| Hazardous Area CCC | No |

| Dimensions | | |
|-------------------------|---------|--|
| Width | 77.9 mm | |
| Depth | 108 mm | |
| Height | 9.8 mm | |
| Weight (including base) | 76 g | |



solutions.abb/800xA solutions.abb/controlsystems

_

800xA and Symphony Plus is a registered trademark of ABB. All rights to other trademarks reside with their respective owners.

We reserve the right to make technical changes to the products or modify the contents of this document without prior notice. With regard to purchase orders, the agreed particulars shall prevail. ABB does not assume any responsibility for any errors or incomplete information in this document. We reserve all rights to this document and the items and images it contains. The reproduction, disclosure to third parties or the use of the content of this document – including parts thereof – are prohibited without ABB's prior written permission.

Copyright© 2024 ABB All rights reserved